

## CONCEPT D 35 D/I L1187W1137 BFLEX DALI 830 7

ARCHITECTURAL LIGHTING

90707L027H70300



### Light distribution



L=1187mm

### PRODUCT DESCRIPTION

**Application Areas:** Architectural, Offices, Hotels and residential, Public spaces, Retail, Art and Culture, Education, Health and care

**Mounting Type:** Suspended

**Control Gear Included:** Yes

**Control Gear:** LED driver 220-240VAC-50/60Hz

## CONCEPT D 35 D/I L1187W1137 BFLEX DALI 830 7

### CHARACTERISTICS

**Luminaire Type:** Triangular luminaire

**Insulation Class:** I

**Ingress Protection (IP):** 40

**Ambient Temperature Range (°C):** ]-5, 25[

**Warranty (Years):** 5

**Current Supply Cable Entry Point:** Back

### MATERIALS

**Body Material:** Extruded aluminium profile

**Finishing:** Epoxy polyester powder coated

**Colour:** Copper (7)

**Glow-wire Resistance (°C):** 960

### OPTICAL SYSTEM

**Optical System:** bFLEX - Opal diffuser

**Light Distribution:** Direct / Indirect

**Beam Angle (°):** 111

### TECHNICAL DATA

**Light Source:** LED

**Input Power (W):** 135

**Input Driver Voltage:** 220-240V-50/60Hz

**Power Factor (λ):** 0,96

**Luminaire Luminous Flux (lm):** 12020

**Luminaire Efficacy (lm/W):** 89

**Unified Glare Rating (UGR):** <25

**LED Lifetime - Rated Median Useful Life:** 70.000h @ L90, B10, Ta 25°C

**CCT - Correlated Colour Temperature (K):** 4000

**Colour Rendering Index (CRI):** >80

**Chromaticity Tolerance (MacAdam step):** <3

**LED Module Forward Voltage Range (VF):** 24

**Power Supply Dimming:** DALI 2

**Central Battery Emergency Lighting System (VDC):** 280-373

**Maximum of Luminaires by Magnetic Circuit Breaker B16:** <45

**CCT - Correlated Colour Temperature (K) [Indirect]:** 3000

### DIMENSIONS

**L - Length (mm):** 1187

**W - Width (mm):** 1137

**H - Height (mm):** 56

### NOTES

- To complete the product it is necessary to order the suspension, the current supply cable and ceiling rose. Please order separately;
- In order to guarantee a total uniformity of light on the ceiling, the installation must be done at a minimum distance of 500 mm;
- The noise level is 20 dB, lower than the typical ambient sound levels recorded in environments such as libraries and reading rooms.